

# **City of Greensboro**

Melvin Municipal
Office Building
300 W. Washington Street
Greensboro, NC 27401

### Agenda Report

File Number: 2024-587

Agenda Item# G.15.

**Agenda Date**: 8/20/2024. **Department:** Engineering & Inspections

Meeting Type: Council Meeting Category: Consent Agenda

**Title:** 2024-587 Resolution Authorizing an Encroachment Agreement between the City of Greensboro and University of North Carolina at Greensboro (UNCG) on Kenilworth Street

within the UNCG Campus

	Council	<b>Priority:</b>	Place an	<b>'</b> x'	in	the	box.
--	---------	------------------	----------	-------------	----	-----	------

⊠Safest City	☐ Most Skilled Workforce
☐ Easiest Place to Do Business	☐Most Connected City
☐Youth Sports Capital	☐ Hub of Recreation and Entertainment
☐ Abundance of Attainable Housing	Other/Admin Briefly Explain 3 word maximum

**Council District**: 4

**Public Hearing:** No

Advertising Date/By: N/A

Contact 1 and Phone: Kenney McDowell, Ext. 2302 Contact 2 and Phone: Jason Geary, Ext. 2302

#### **PURPOSE:**

To grant an Encroachment Agreement in City right-of-way for the installation of approximately 100 LF of underground ductile iron chilled water supply and return lines. When public or private entities request to use City right-of-way, it is required that they secure approval by City Council.

#### **BACKGROUND:**

The University of North Carolina at Greensboro approached the City in order to request placement of underground chilled water lines in City right-of-way. The chilled water lines will be used to manage the temperature and humidity levels within the large campus buildings.

This encroachment involves the installation of approximately 100 LF of 12" ductile iron chilled water lines on Kenilworth Street within the UNCG Campus. The plans for this installation have been approved by City staff and the Technical Review Committee.

#### **BUDGET IMPACT:**

There is no budget impact. All associated costs will be incurred by University of North Carolina at Greensboro.

### **ACCOUNT NUMBER:**

N/A

## **RECOMMENDATION / ACTION REQUESTED:**

The Engineering & Inspections Department recommends that City Council grant the University of North Carolina at Greensboro an Encroachment Agreement for the use of installing these chilled water lines in City right-of-way